

PERFORMANCE RESULTS

Coronie B.V.
Hoge Hereweg 18, 9756 TH Glimmen
The Netherlands

EN 12566-3:2005 +A1:2009 Annex B
Small wastewater treatment systems for up to 50 PT

Small wastewater treatment system BIOROCK-D5
Aerobic biological gravity Filter


Nominal organic daily load	0.27	kg/d
Nominal hydraulic daily load	0.75	m³/d
Material	Polyethylene (PE)	
Treatment efficiency (nominal sequences)	COD	96.3 %
	BOD₅	98.7 %
	SS	99.3 %
Electrical consumption	0.0	kWh/d

Performance tested by:


PIA - Prüfinstitut für Abwassertechnik GmbH
(PIA GmbH)
Hergentrather Weg 30
D-52074 Aachen

Certified according to
ISO 9001:2000



Notified Body number: 1739 

This document replaces neither the declaration
of conformity nor the CE marking.

Prüfinstitut für Abwassertechnik GmbH

geprüft - tested - teste

Elmar Lancé

February 2012